

FIRE EXTINGUISHER INSPECTION LIST

	Extinguisher Serial Number	Location	Comments/Notes	Expiration Date	
1	D-57622216	6000 Gal AST	EXPEDED - Replace	2023	
2	D-57623256	inside bulk Tank Fence	fully charged	2023	
3	BX-948920	inside 3000 gal tank fence	↓	2023	
4	D-57622728	Boiler Bldg		2023	
5	D-57623697	1000Gal Bus Barn Tank		2023	
6	unknown	10 Extinguishers in 55 gal open top drums in spill Est		uninspectable	unknown
7					
8					
9					
10					