

SITE VISIT SERVICE SUMMARY

LOCATION: *Allakaket*

ENTITY: *YESD*

TECHNICIAN: *Michael Clarke*

DATE: *14 June 2021*

FACILITY INSPECTION

FACILITY TRAINING

MAINTENANCE
*- removed / re-sealed / re-installed shut-off valve on top of 1000 gal Bus Bern Tank.
- Tightened AB's Siphon Valve on 3000 gal IT.*

DISPENSER WORK

PRESSURE TEST

HAZWOPER TRAINING

ANNUAL TANK FARM INSPECTION

OTHER/NOTES
School currently undergoing construction.



FRONTIER
FUEL SERVICE, LLC