

FIRE EXTINGUISHER INSPECTION LIST

	Extinguisher Serial Number	Location	Comments/Notes	Expiration Date
1	BK 948920	3k tank (Grey tank)	expired - Dated 2013	2019
2	D57622216	6k Bolt tank @ gate	Unserviceable expired / Discharged - Dated 2017	2023
3	D57623256	Bolt storage fence @ gate	expires next ^{next} year - Dated 2017	2023
4	D57623697	Bus Barn tank	fully charged - Dated 2017	2023
5	2 x 10 lbs	Sprinkler Bldg / Spill list	expired - Dated 2013	2019
6	3 x 20 lbs	Sprinkler Bldg / Spill list	expired - Dated 2013	2019
7				
8				
9				
10				



FRONTIER
FUEL SERVICE, LLC

7362 W Parks Hwy #235, Wasilla, AK 99623