

SITE VISIT SERVICE SUMMARY

LOCATION: *Allabet*

ENTITY: *YKSD*

TECHNICIAN: *M. Clarke*

DATE: *16-23 May 2022*

FACILITY INSPECTION

See Discrepancy Report & individual tank inspection sheets

FACILITY TRAINING

MAINTENANCE

Repaired 1 leak @ New 5k water plant tank. Repaired 2 leaks @ 3k tank next to Boiler/Mechanical Bldg. Replaced leaking filters @ Bus Barn tank.

DISPENSER WORK

PRESSURE TEST

HAZWOPER TRAINING

ANNUAL TANK FARM INSPECTION

See Facility Discrepancy Report & Annual inspection sheets

OTHER/NOTES

3k tank is currently empty due to fuel transfer to accommodate repairs.



FRONTIER
FUEL SERVICE, LLC