


FIRE EXTINGUISHER INSPECTION LIST

	Extinguisher Serial Number	Location	Comments/Notes	Expiration Date
1	H-13437443	3k Tank fence	Billy Charged, Dated 2022	2028
2	G-98128729	6k Tank, fill box	Billy Charged, Dated 2021	2027
3	D-57623256	6k Tank fight pole	Billy Charged, Serviced 2022	2028
4	D-57623697	1k Bustam Tank	Billy Charged, Serviced 2022	2028
5	3 @ 20155 2 @ 10155	fire suppression blobs 55-Gal Drum	Billy Charged, Dated 2013 EXPIRED	2019
6				
7				
8				
9				
10				



FRONTIER
FUEL SERVICE LLC

7362 W Parks Hwy #235, Wasilla, AK 99623