

# SITE VISIT SERVICE SUMMARY

LOCATION: *Allakabof*

ENTITY: *YKSD*

TECHNICIAN: *M. Clarke*

DATE: *21-22 June 2023*

FACILITY INSPECTION

FACILITY TRAINING

MAINTENANCE  
*Tightened leaking Anti-Siphon Valve and union, unplugged Bill alarm and installed vent.*

DISPENSER WORK

PRESSURE TEST

HAZWOPER TRAINING

ANNUAL TANK FARM INSPECTION  
*See Inspection Worksheets and Discrepancy Report for details.*

OTHER/NOTES



**FRONTIER**  
FUEL SERVICE, LLC