



	YES	NO	COMMENTS/ACTIONS REQUIRED
29 Is the tank foundation in good condition?			
30 Is the paint on the tank in good condition?			
31 Is the product leveler? (One on each side of the tank)			
32 Is the confined space placard visible?			
33 Are all valves closed and locked?			
<b>NOTE: This section pertains to the roof of the tank.</b>			
34 Are the tank accessories and roof in good condition?			
35 Is the confined space placard visible (top)?			
36 Is the "Safe Fill Limit" written on top of the tank?			
<b>Diesel Tanks</b>			
37 Is the tank exterior in good condition and free of any indications of exterior shell leaks?			
38 Is the tank free of any indications of corrosion or shell distortion?			
39 Is the tank foundation in good condition?			
40 Is the paint on tank in good condition?			
41 Is the product leveler? (One on each side of the tank)			
42 Is the confined space placard visible?			
43 Are all valves closed and locked?			
<b>NOTE: This section pertains to the roof of the tank.</b>			
44 Are the tank accessories and roof in good condition?			
45 Is the confined space placard visible (top)?			
46 Is the "Safe Fill Limit" written on top of the tank?			
<b>Other Tanks</b>			
47 Is the State, Federal or OSHA posters currently displayed?			
48 Are fire extinguishers in good working condition and tags current?			
49 Is the "ADSC of-1" and no smoking signs visible?			
50 Is there a copy of Facility Response Plan available?			
51 Is the container locked and secured?			
<b>NOTE:</b>			
During inspection note of discrepancies in any of the above mentioned items and report them immediately to your manager and fax a copy RAFS Operations in Anchorage (907) 632621 or FAX 1-877-582435			
Inspected by: <u>JAYME MOSES</u> Date: <u>07/29/14</u>			
Additional Notes:			
<u>None</u>			
<u>Need Shinsling</u>			