



Rural Alaska Fuel Services

Date: 03/28/14 Village: Healy

Company: YKSD

Spill Awareness Drill

What type of spill has occurred? What is the worst case scenario?

50 gallon spill at school also

Who was the first responder to the spill and what was the first action taken?

Todd was first responder, shut off valve to stop over flow.

What task force security measures were taken to contain the spill?

Put down drip pads and close gate.

What measures were taken to secure the public from the spill?

Close off area with Do not enter signs.

Which PPE (personal protection equipment) was used?

Rubber boots and gloves.

What method was used to clean up the contamination?

blended with the ~~material~~ ~~material~~ ~~material~~

Who was notified of the spill and how were they contacted?

Terry Stanton - by phone

What was the cause of the spill?

Operator mistake

Multi-stage tank ~~in front you are doing~~ final levels

Please have all participants sign below?

Todd Pomeroy