



RAFSS Discrepancy Report

(Write in client needs on-site)

- Location: Hughes
- Date: 2/13/16

* Fire extinguishers in tank farm
and at day tank expired 2012,
please order (3)

• RAFS Technician Signature: [Signature]